


Government of Nepal
Ministry of Federal Affairs Local Development
Department of Local Infrastructure Development and Agricultural Roads (DoLIDAR)
Project for Strengthening the National Rural Transport Program (SNRTP)
Central Project Coordination Unit (CPCU)
Nepal Administrative Staff College, Jawalakhel, Lalitpur
Date: June 15, 2015

Clarification Notice No. 1

This is to notify that Ministry of Federal Affairs Local Development Department of Local Infrastructure Development and Agricultural Roads (DoLIDAR) Project for Strengthening the National Rural Transport Program (SNRTP) Central Project Coordination Unit (CPCU), Jawalakhel, Lalitpur has issued the following clarifications on the queries raised by the bidders regarding the bidding document for the Procurement of Goods (Portable Electric Generator) Contract ID No: SNRTP-CPCU-G-NCB-14-071-72, published on May 26, 2015 in the Annapurna Post National Daily Newspaper .

Sl No.	Reference	Queries from the Bidders	Response by the purchaser
1.	In Technical Specification, Page no 61, Particular Engine	You have asked for air cooled engine. Please let us make clear that Liquid cooled engine will be acceptable for you or not. How tender will be evaluated if any bidder offers liquid cooled engine . Since liquid cooled engines are versatile and you might get more bidders for liquid cooled engine. Liquid cooled engines without cold starting are also suitable to run at those destinations mentioned in tender document.	In case of air cooled engine there will be no change. We stand by for the same as mentioned in bid documents. The evaluation will be done as per set specification.
2	In Technical Specification, Page no 61 & 63, Particular - Capacity	You have asked 50/60 Hz. 60Hz is not standard for Nepal so Please let us clear about same	Please refer to addendum Notice No. 1



(Mr. Ashok Kumar Jha)
Deputy Program Coordinator